



SANDEEP FIRE SERVICES

AUTHORISED LICENSE AGENCY NO- MFS-LA/F-0572

ISO 9001 2015

9923236015 / 9822004863

Head Office S.R.no 84/2, Saidapur, Sambhaji Nagar, Medha Road, Post Kondave, Tal-Dist Satara. 415 002



Date :- 11/01/2021

TEST WARRANTY CERTIFICATE

This is certify that following Fire Extinguisher have been Tested & Refilling by us per relevent IS specification and supplied to

To.

Principal.

Yashawantrao Chavan Institute of science,
Satara.

List of Total Fire extinguisher in College Campus.

Sr.No	Location	Type of Fire Extinguisher	Qty	Refilling Date	Next Due Date
1.	Office	Co2 4.5Kg	1	06-01-2021	05-01-2022
		ABC 6 Kg	1		
2.	Ele	co2 2kg	1	06-01-2021	05-01-2022
		co2 4.5kg	1	06-01-2021	05-01-2022
3.	BCS A 3 -2	ABC 6 kg	2	06-01-2021	05-01-2022
4.	Biotech	co2 2kg	1	06-01-2021	05-01-2022
5.	Library Dept.	ABC 6 Kg	2	06-01-2021	05-01-2022
	Statistics A 2- 2	Co2 2 Kg	1	06-01-2021	05-01-2022
7.	A Building MPSC office	ABC 2 kg	1	06-01-2021	05-01-2022
8.	A building Animation science	co2 2kg	1	06-01-2021	05-01-2022
9.	KIIT A 2 -10	co2 2kg	1	06-01-2021	05-01-2022
10.	M building Zoology	ABC 6 Kg	2	06-01-2021	05-01-2022
11.	M building MSC Lab Mo13	ABC 6 Kg	1	06-01-2021	05-01-2022
12.	M building PHD Lab Mo14	ABC 6 Kg	1	06-01-2021	05-01-2022
13.	Physics lab M 20	ABC 6 Kg	1	06-01-2021	05-01-2022
		Co2 2Kg	1	06-01-2021	05-01-2022
		ABC 5 Kg	1	06-01-2021	05-01-2022
14.	Physics lab Mo24	ABC 6 Kg	1	06-01-2021	05-01-2022
15.	Research lab M1-9	ABC 6 Kg	1	06-01-2021	05-01-2022
16.	in quelity M 0 1	co2 2kg	1	06-01-2021	05-01-2022
17.	Micro MSC lab M1-10B	ABC 6 Kg	1	06-01-2021	05-01-2022



SANDEEP FIRE SERVICES

AUTHORISED LICENSE AGENCY NO- MFS-LA/F-0572

ISO 9001 2015

9923236015 / 9822004863

Head Office - S.R.no 84/2, Saidapur, Sambhaji Nagar, Medha Road, Post Kondave, Tal-Dist Satara. 415 002

Sr.No	Location	Type of Fire Extinguisher	Qty	Refilling Date	Next Due Date
18.	Micro lab.M1-13,	ABC 6 Kg	1	06-01-2021	05-01-2022
19.	Micro lab.M1-15	ABC 2kg	1	06-01-2021	05-01-2022
20.	Micro lab. M1-16	ABC 6 Kg	1	06-01-2021	05-01-2022
21.	Micro Research lab M1-17	ABC 2kg	1	06-01-2021	05-01-2022
22.	Botany Dept M 1 2	ABC 6 Kg	1	06-01-2021	05-01-2022
				06-01-2021	05-01-2022
	Botany Dept. M1-5	ABC 6 Kg	1	06-01-2021	05-01-2022
24.	Botany lab M1-8	ABC 6 Kg	1	06-01-2021	05-01-2022
25.	M Building outside 2 floor	ABC 6 Kg	2	06-01-2021	05-01-2022
			2	06-01-2021	05-01-2022
26.	CET study Room	ABC 6 Kg	1	06-01-2021	05-01-2022
27.	D Building chemistry lab D 02	ABC 6 Kg	1	06-01-2021	05-01-2022
28.	D Building chemistry lab	ABC 6 Kg	2	06-01-2021	05-01-2022
29.	Chemical store Room	ABC 6 Kg	1	06-01-2021	05-01-2022
30.	Chemistry	ABC 6 Kg	2	06-01-2021	05-01-2022
		ABC 5 Kg	2	06-01-2021	05-01-2022
31.	chemistry MSC lab	ABC 6 Kg	1	06-01-2021	05-01-2022
32.	forensic science lab	co2 4.5kg	1	06-01-2021	05-01-2022
33.	B Building Computer lab B1 7	co2 2kg	1	06-01-2021	05-01-2022
34.	Electrical Dip. B 1	ABC 6 kg	1	06-01-2021	05-01-2022
35.	Jr Physics B 1 3	ABC 2 Kg	1	06-01-2021	05-01-2022
36.	Jr Physics B 1 1	ABC 2 Kg	1	06-01-2021	05-01-2022
37.	Jr. Biology B 2 1	ABC 2 Kg	1	06-01-2021	05-01-2022
38.	Jr. Biology B 2 5	ABC 2 Kg	1	06-01-2021	05-01-2022
39.	Food Packaging B 2 8	ABC 6 Kg	1	06-01-2021	05-01-2022
40.	Nano lab B-2	ABC 6 Kg	1	06-01-2021	05-01-2022
41.	Girl Hostel mess & 3 floor	ABC 6 Kg	4	06-01-2021	05-01-2022
42.	MLT Lab	ABC 5 Kg	1	06-01-2021	05-01-2022
43.	Electronics	co2 2kg	1	06-01-2021	05-01-2022
44.	Electrical	co2 2kg	1	06-01-2021	05-01-2022
45.	Gymkhana	ABC 6 Kg	1	06-01-2021	05-01-2022



SANDEEP FIRE SERVICES

AUTHORISED LICENSE AGENCY NO- MFS-LA/F-0572

ISO 9001 2015

9923236015 / 9822004863

Head Office - S.R.no 84/2, Saidapur, Sambhaji Nagar, Medha Road, Post Kondave, Tal-Dist Satara. 415 002

Sr.No	Location	Type of Fire Extinguisher	Qty	Refilling Date	Next Due Date
46	Canting	ABC 6 Kg	1	06-01-2021	05-01-2022
47	NCC Dept	ABC 10 Kg	1	06-01-2021	05-01-2022
48	New Hall	ABC 6 Kg	2	06-01-2021	05-01-2022
49	Security cabin	ABC 6 Kg	2	06-01-2021	05-01-2022
50	Mpsc Library	ABC 6 Kg	1	06-01-2021	05-01-2022
51	animation B-2-0	ABC 6 Kg	1	06-01-2021	05-01-2022
52	Mathematics Dipartment B-3- 0	ABC 6 Kg	1	06-01-2021	05-01-2022
53	G ground Floor	co2 4.5kg	1	06-01-2021	05-01-2022
54	G First Floor	ABC 6 Kg	1	06-01-2021	05-01-2022
55	G Second Floor	ABC 6 Kg	2	06-01-2021	05-01-2022
56	G Third Floor	ABC 6 Kg	1	06-01-2021	05-01-2022
57	R & D G Thied Floor	ABC 6 Kg	1	06-01-2021	05-01-2022
58	R & D work Shop	ABC 6 Kg	3	06-01-2021	05-01-2022
59	G Fourth Floor	ABC 6 Kg	1	06-01-2021	05-01-2022
Total Fire Extinguisher			81		

Summary

Sr. No	Type of Fire Extinguisher	Capacity	Total Quantity
1	ABC Store pressure Type of Fire Extinguisher	2 Kg	7 Nos
		5 Kg	4 Nos
		6 Kg	55 Nos
		10 Kg	1 Nos
2	Co2 Type of Fire Extinguisher	2 Kg	10 Nos
		4.5 Kg	4 Nos
Total Quantity Of Fire Extinguisher			81 nos

Approved By

For SANDEEP FIRE SERVICES
M/s. Sandeep Fire Services

Sandeep 
PROPRIETOR
(Fire & Safety Engg)
Auth. sign